



Specification and General Notes:

1. All components MMCD PLATINUM (Section 33 44 01) compliant and fabricated to CSA CERTIFICATE OF COMPLIANCE (ASTM C478M)
2. All jurisdiction-specific components SUPPLEMENTAL to MMCD PLATINUM fabricated in accordance with CSA CERTIFICATE OF QUALIFICATION (CSA A23.4-09).
3. Components certified to CSA standards (ASTM C478M & CSA A23.4-09) by approved independent third party certification body accredited by Standards Council of Canada.
4. All components marked with certification body logo and CSA standard markings.
5. Testing to ASTM C497/CSA 23.1 & 2-09.
6. 30 MPa MIN compressive strength (MAX 0.5 W/C ratio).
7. Pipe penetrations to be grouted unless otherwise noted
8. 25mm MIN concrete cover of reinforcing steel.
9. 5mm manufacturing tolerance.
10. A-3 concrete exposure class.
11. 15MPa MIN stripping strength.
12. Standard grade form finish.
13. Unformed steel trowel or wood float finish.
14. 3 point rigging to meet WORK SAFE BC OHS (Guideline 14/15) requirement.
15. Field installation and testing by others.

BILL OF MATERIALS			
ITEM	DESCRIPTION	MASS KG	QUANTITY
1	2448CBTT	520	1
2	24DLCGF	834	1
3	CBDR2	24	AS REQ.
4	D24D OR D24F	59	1
5	D23 - GRATE	54	1
6	D-TRAPHOOD	10	1



Description:
Curb Catchbasin Type V
 BBY - S110

Jurisdiction: City of Burnaby

Drawn : S.d.
 Date : 20/09/2016
 Approved :
 Load Rating: H20
 Rev. No.
 Scale : 1:15

Catalog No.
Dwg. No.
CoBBY-3

7520 Conrad Street Burnaby, B.C. V5A 2H7 Phone : 604-415-5181 Fax : 604-415-5185
 www: diamondprecast.com

This drawing is the property of the Diamond Precast Concrete. All information contained herein is confidential and may not be used in whole or in part without written permission from the owner

Sheet No.
 1 OF 1