



BILL OF MATERIALS

ITEM	DESCRIPTION	MASS KG	QUANTITY
1	2448CBS	520	2
2	2406R, 2412R, 2424R, 2436R		AS REQ
3	24DLROM	49	2
4	DI84BURR-FRAME	70	2
5	DI8-GRATE	48	1
6	DI8BURR-STORM	65	1

Specification and General Notes:

- Maximum paved area serviced: 600m²
- All components MMCD PLATINUM (Section 33 44 01) compliant and fabricated to CSA CERTIFICATE OF COMPLIANCE (ASTM C478M)
- All jurisdiction-specific components SUPPLEMENTAL to MMCD PLATINUM fabricated in accordance with CSA CERTIFICATE OF QUALIFICATION (CSA A23.4-09).
- Components certified to CSA standards (ASTM C478M & CSA A23.4-09) by approved independent third party certification body accredited by Standards Council of Canada.
- All components marked with certification body logo and CSA standard markings.
- Testing to ASTM C497/CSA 23.1 & 2-09.
- 30 MPa MIN compressive strength (MAX 0.5 W/C ratio).
- Pipe penetrations to be grouted unless otherwise noted
- 25mm MIN concrete cover of reinforcing steel.
- 5mm manufacturing tolerance.
- A-3 concrete exposure class.
- 15MPa MIN stripping strength.
- Standard grade form finish.
- Unformed steel trowel or wood float finish.
- 3 point rigging to meet WORK SAFE BC OHS (Guideline 14/15) requirement.
- Field installation and testing by others.



Description:

Oil Interceptor 600mm
BBY - SII9

Jurisdiction: City of Burnaby

Drawn :	Date :	Catalog No.
S.d.	20/09/2016	
Approved :	Load Rating:	Dwg. No.
	N/A	
Rev. No.	Scale :	CoBBY-6
	1:15	

7520 Conrad Street Burnaby, B.C. V5A 2H7 Phone : 604-415-5181 Fax : 604-415-5185
www: diamondprecast.com

This drawing is the property of the Diamond Precast Concrete. All information contained herein is confidential and may not be used in whole or in part without written permission from the owner

Sheet No.
1 OF 1